



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Stack Emission Monitoring Report

Report No.: ME-NG5091-180406-SA-RIPL-AMRAVATI			Date: 06.04.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description /Type	Stack Emission Monitoring	Sample Collected by	Laboratory
Sampling Location	Unit No.1	Sample Quantity/Packing	Thimble: 1 X 1 No. SO ₂ : 30 mL X 1No.PVC Bottle NO _x :25 mL X 1No.PVC Bottle Bladder: 1L X 1 No.
Date of Sampling	26.03.2018	Date of Receipt of Sample	26.03.2018
Sampling Procedure	As per Method Reference		
Date of Start of Analysis	27.03.2018	Date of Completion of Analysis	04.04.2018

Stack No.		Unit No.1		
Stack attached to		ESP of Boiler Unit No.1		
Material of construction		M.S.		
Stack height above ground level (Meter)		275.0		
Stack diameter (Meter)		4.6		
Stack shape at top		Round		
Type of fuel		Coal		
Fuel Consumption (t/h)		140		
ESP Fields (28 No's.)		In Service (28 No's)		
Load at the time of monitoring		270 MW		
Parameter	Unit	Result	Limit as Per Consent	Method Reference
Flue gas Temperature	⁰ C	145	-	IS 11255 (Part 3):2008
Flue gas Velocity	m/s	30.9	-	IS 11255 (Part 3):2008
Total gas quantity	Nm ³ /h	1317305	-	IS 11255 (Part 3):2008
Particulate Matter (PM)	mg/Nm ³	32	50	IS 11255 (Part 1):1985 RA 2003
Sulphur Dioxide (SO ₂)	mg/Nm ³	552	-	IS 11255 (Part 2):1985 RA 2003




Report No.5091 cont...

Parameter	Unit	Result	Limit as Per Consent	Method Reference
Sulphur Dioxide (SO ₂)	kg/day	17452	52230	IS 11255 (Part 2):1985 RA 2003
Oxides of Nitrogen(NO _x)	mg/Nm ³	217	-	IS 11255 (Part 7):2005
Carbon Dioxide (CO ₂)	%	12.8	-	IS 13270:1992, RA 2009
Remarks :				

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Stack Emission Monitoring Report

Report No.: ME-NG4098-180326-SA-RIPL-AMRAVATI			Date: 26.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description /Type	Stack Emission Monitoring	Sample Collected by	Laboratory
Sampling Location	Unit No.2	Sample Quantity/Packing	Thimble: 1 X 1 No. SO ₂ : 30 mL X 1No.PVC Bottle NO _x :25 mL X 1No.PVC Bottle Bladder: 1L X 1 No.
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	As per Method Reference		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	22.03.2018

Stack No.		Unit No.2		
Stack attached to		ESP of Boiler Unit No.2		
Material of construction		M.S.		
Stack height above ground level (Meter)		275.0		
Stack diameter (Meter)		4.6		
Stack shape at top		Round		
Type of fuel		Coal		
Fuel Consumption (t/h)		130		
ESP Fields (28 No's.)		In Service (28 No's)		
Load at the time of monitoring		270 MW		
Parameter	Unit	Result	Limit as Per Consent	Method Reference
Flue gas Temperature	⁰ C	130	-	IS 11255 (Part 3):2008
Flue gas Velocity	m/s	29.2	-	IS 11255 (Part 3):2008
Total gas quantity	Nm ³ /h	1294792	-	IS 11255 (Part 3):2008
Particulate Matter (PM)	mg/Nm ³	36	50	IS 11255 (Part 1):1985 RA 2003
Sulphur Dioxide (SO ₂)	mg/Nm ³	556	-	IS 11255 (Part 2):1985 RA 2003




Report No.4098 cont...

Parameter	Unit	Result	Limit as Per Consent	Method Reference
Sulphur Dioxide (SO ₂)	kg/day	16300	52230	IS 11255 (Part 2):1985 RA 2003
Oxides of Nitrogen(NO _x)	mg/Nm ³	226	-	IS 11255 (Part 7):2005
Carbon Dioxide (CO ₂)	%	12.3	-	IS 13270:1992, RA 2009
Remarks :				

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Stack Emission Monitoring Report

Report No.: ME-NG5092-180406-SA-RIPL-AMRAVATI			Date: 06.04.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description /Type	Stack Emission Monitoring	Sample Collected by	Laboratory
Sampling Location	Unit No.2	Sample Quantity/Packing	Thimble: 1 X 1 No. SO ₂ : 30 mL X 1No.PVC Bottle NO _x :25 mL X 1No.PVC Bottle Bladder: 1L X 1 No.
Date of Sampling	26.03.2018	Date of Receipt of Sample	27.03.2018
Sampling Procedure	As per Method Reference		
Date of Start of Analysis	28.03.2018	Date of Completion of Analysis	04.04.2018

Stack No.		Unit No.2		
Stack attached to		ESP of Boiler Unit No.2		
Material of construction		M.S.		
Stack height above ground level (Meter)		275.0		
Stack diameter (Meter)		4.6		
Stack shape at top		Round		
Type of fuel		Coal		
Fuel Consumption (t/h)		137		
ESP Fields (28 No's.)		In Service (28 No's)		
Load at the time of monitoring		270 MW		
Parameter	Unit	Result	Limit as Per Consent	Method Reference
Flue gas Temperature	⁰ C	139	-	IS 11255 (Part 3):2008
Flue gas Velocity	m/s	30.3	-	IS 11255 (Part 3):2008
Total gas quantity	Nm ³ /h	1310538	-	IS 11255 (Part 3):2008
Particulate Matter (PM)	mg/Nm ³	35	50	IS 11255 (Part 1):1985 RA 2003
Sulphur Dioxide (SO ₂)	mg/Nm ³	558	-	IS 11255 (Part 2):1985 RA 2003




Report No.5092 cont...

Parameter	Unit	Result	Limit as Per Consent	Method Reference
Sulphur Dioxide (SO ₂)	kg/day	17551	52230	IS 11255 (Part 2):1985 RA 2003
Oxides of Nitrogen(NO _x)	mg/Nm ³	208	-	IS 11255 (Part 7):2005
Carbon Dioxide (CO ₂)	%	12.1	-	IS 13270:1992, RA 2009
Remarks :				

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Stack Emission Monitoring Report

Report No.: ME-NG5093-180406-SA-RIPL-AMRAVATI			Date: 06.04.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description /Type	Stack Emission Monitoring	Sample Collected by	Laboratory
Sampling Location	Unit No.4	Sample Quantity/Packing	Thimble: 1 X 1 No. SO ₂ : 30 mL X 1No.PVC Bottle NO _x :25 mL X 1No.PVC Bottle Bladder: 1L X 1 No.
Date of Sampling	26.03.2018	Date of Receipt of Sample	27.03.2018
Sampling Procedure	As per Method Reference		
Date of Start of Analysis	27.03.2018	Date of Completion of Analysis	04.04.2018

Stack No.		Unit No.4		
Stack attached to		ESP of Boiler Unit No.4		
Material of construction		M.S.		
Stack height above ground level (Meter)		275.0		
Stack diameter (Meter)		4.6		
Stack shape at top		Round		
Type of fuel		Coal		
Fuel Consumption (t/h)		137		
ESP Fields (28 No's.)		In Service (28 No's)		
Load at the time of monitoring		270 MW		
Parameter	Unit	Result	Limit as Per Consent	Method Reference
Flue gas Temperature	⁰ C	139	-	IS 11255 (Part 3):2008
Flue gas Velocity	m/s	30.3	-	IS 11255 (Part 3):2008
Total gas quantity	Nm ³ /h	1310538	-	IS 11255 (Part 3):2008
Particulate Matter (PM)	mg/Nm ³	32	50	IS 11255 (Part 1):1985 RA 2003
Sulphur Dioxide (SO ₂)	mg/Nm ³	560	-	IS 11255 (Part 2):1985 RA 2003




Report No.5093 cont...

Parameter	Unit	Result	Limit as Per Consent	Method Reference
Sulphur Dioxide (SO ₂)	kg/day	17614	52230	IS 11255 (Part 2):1985 RA 2003
Oxides of Nitrogen(NO _x)	mg/Nm ³	209	-	IS 11255 (Part 7):2005
Carbon Dioxide (CO ₂)	%	11.8	-	IS 13270:1992, RA 2009
Remarks :				

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Stack Emission Monitoring Report

Report No.: ME-NG4099-180308-SA-RIPL-AMRAVATI			Date: 08.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description /Type	Stack Emission Monitoring	Sample Collected by	Laboratory
Sampling Location	Unit No.5	Sample Quantity/Packing	Thimble: 1 X 1 No. SO ₂ : 30 mL X 1No.PVC Bottle NO _x :25 mL X 1No.PVC Bottle Bladder: 1L X 1 No.
Date of Sampling	15.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	As per Method Reference		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	22.03.2018

Stack No.		Unit No.5		
Stack attached to		ESP of Boiler Unit No.5		
Material of construction		M.S.		
Stack height above ground level (Meter)		275.0		
Stack diameter (Meter)		4.6		
Stack shape at top		Round		
Type of fuel		Coal		
Fuel Consumption (t/h)		132		
ESP Fields (28 No's.)		In Service (28 No's)		
Load at the time of monitoring		270 MW		
Parameter	Unit	Result	Limit as Per Consent	Method Reference
Flue gas Temperature	⁰ C	137	-	IS 11255 (Part 3):2008
Flue gas Velocity	m/s	30.2	-	IS 11255 (Part 3):2008
Total gas quantity	Nm ³ /h	1312584	-	IS 11255 (Part 3):2008
Particulate Matter (PM)	mg/Nm ³	30	50	IS 11255 (Part 1):1985 RA 2003
Sulphur Dioxide (SO ₂)	mg/Nm ³	535	-	IS 11255 (Part 2):1985 RA 2003




Report No.4099 cont...

Parameter	Unit	Result	Limit as Per Consent	Method Reference
Sulphur Dioxide (SO ₂)	kg/day	16854	52230	IS 11255 (Part 2):1985 RA 2003
Oxides of Nitrogen(NO _x)	mg/Nm ³	232	-	IS 11255 (Part 7):2005
Carbon Dioxide (CO ₂)	%	12.5	-	IS 13270:1992, RA 2009
Remarks :				

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Ambient Air Quality Monitoring Report

Report No.: ME-NG4099-180328-SA-RIPL-AMRAVATI		Date: 28.03.2018	
Name and address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901	Order Reference:	
		SO No. 3382012035 dtd. 21.09.2015.	
Sample Description /Type	Ambient Air Quality Monitoring	Sample Collected by	Laboratory
Sampling Location	1) Near Site Office 2) Terrace of WTP Plant Building 3) Terrace of Bachelor Guest House	Sample Quantity / Packing	Filter Paper (PM ₁₀): 3 X 3 No. Filter Paper (PM _{2.5}): 1 X 3 No. SO ₂ : 30mL X18 No. PVC Bottle NO ₂ : 30mL X18 No. PVC Bottle NH ₃ : 30 mL X18 No. PVC Bottle O ₃ : 10 mL X 72 No. PVC Bottle 3 X 12 No. Charcoal Tubes 3 X 3 No. Rubber Bladder
Date of Sampling	15.03.2018 & 16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	As per Method reference		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	23.03.2018

Meteorological Data/Environmental Conditions					
Avg. Wind Velocity	Prominent Wind Direction	Relative Humidity (%)		Temperature (°C)	
2.9 km/h	SE	Max.	Min.	Max.	Min.
		38	20	38.0	24.0
Location	1) Near Site Office			Duration of Survey : 24 hours	
Parameter	Unit	Result	#NAAQM Standard	Method Reference	
Sulphur Dioxide (SO ₂)	µg/m ³	14.8	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6	
Nitrogen Dioxide (NO ₂)	µg/m ³	18.2	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10	
Particulate Matter (size less than 10µm) or PM ₁₀	µg/m ³	90	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14	
Particulate Matter (size less than 2.5µm) or PM _{2.5}	µg/m ³	46	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13,Page No.15-30	
Ozone (O ₃)	µg/m ³	<19.6	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13,Page No.31-34	
Lead (as Pb)	µg/m ³	<0.02	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55	

Report No.4099 Cont...

Parameter	Unit	Result	#NAAQM Standard	Method Reference
Carbon Monoxide(CO)	mg/m ³	0.78	4.0	IS 5182 (Part 10):1999 RA 2003
Ammonia (NH ₃)	µg/m ³	32.6	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
Benzene (C ₆ H ₆)	µg/m ³	1.3	5.0	IS 5182 (Part 11): 2006
Benzo (a) Pyrene (Particulate phase only)	ng/m ³	<0.5	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
Arsenic (as As)	ng/m ³	<0.3	6.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Nickel (as Ni)	ng/m ³	<3	20.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Mercury (as Hg)	µg/m ³	<0.06	-	Method of analysis of Hg & MoF Japan
Location	2) Terrace of WTP Plant			Duration of Survey : 24 hours
Sulphur Dioxide (SO ₂)	µg/m ³	10.4	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
Nitrogen Dioxide (NO ₂)	µg/m ³	15.8	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
Particulate Matter (size less than 10µm) or PM ₁₀	µg/m ³	80	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
Particulate Matter (size less than 2.5µm) or PM _{2.5}	µg/m ³	40	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
Ozone (O ₃)	µg/m ³	<19.6	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34
Lead (as Pb)	µg/m ³	<0.02	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Carbon Monoxide(CO)	mg/m ³	0.78	4.0	IS 5182 (Part 10):1999 RA 2003
Ammonia (NH ₃)	µg/m ³	30.6	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
Benzene (C ₆ H ₆)	µg/m ³	1.1	5.0	IS 5182 (Part 11): 2006
Benzo(a)Pyrene (Particulate phase only)	ng/m ³	<0.5	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
Arsenic (as As)	ng/m ³	<0.3	6.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Nickel (as Ni)	ng/m ³	<3	20.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55

Report No.4099 Cont...

Parameter	Unit	Result	#NAAQM Standard	Method Reference
Location	2) Terrace of WTP Plant			Duration of Survey : 24 hours
Mercury (as Hg)	$\mu\text{g}/\text{m}^3$	<0.06	-	Method of analysis of Hg & MoF Japan
Parameter	Unit	Result	#NAAQM Standard	Method Reference
Location	3) Terrace of Bachelor Guest House			Duration of Survey : 24 hours
Sulphur Dioxide (SO ₂)	$\mu\text{g}/\text{m}^3$	11.8	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
Nitrogen Dioxide (NO ₂)	$\mu\text{g}/\text{m}^3$	12.6	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
Particulate Matter (size less than 10 μm) or PM ₁₀	$\mu\text{g}/\text{m}^3$	74	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
Particulate Matter (size less than 2.5 μm) or PM _{2.5}	$\mu\text{g}/\text{m}^3$	36	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
Ozone (O ₃)	$\mu\text{g}/\text{m}^3$	<19.6	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34
Lead (as Pb)	$\mu\text{g}/\text{m}^3$	<0.02	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Carbon Monoxide(CO)	mg/m^3	0.72	4.0	IS 5182 (Part 10):1999 RA 2003
Ammonia (NH ₃)	$\mu\text{g}/\text{m}^3$	28.7	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
Benzene (C ₆ H ₆)	$\mu\text{g}/\text{m}^3$	<1	5.0	IS 5182 (Part 11): 2006
Benzo(a)Pyrene (Particulate phase only)	ng/m^3	<0.5	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
Arsenic (as As)	ng/m^3	<0.3	6.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Nickel (as Ni)	ng/m^3	<3	20.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Mercury (as Hg)	$\mu\text{g}/\text{m}^3$	<0.06	-	Method of analysis of Hg & MoF Japan
Remarks: N.D. - Not Detected; TWA - Time Weighted Average., #- NAAQS specified as: 24h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM ₁₀ , PM _{2.5} , Lead and Ammonia; 1h. TWA in case of Carbon Monoxide and Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.				

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Ambient Air Quality Monitoring Report

Report No.: ME-NG5094-180406-SA-RIPL-AMRAVATI			Date: 06.04.2018
Name and address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description / Type	Ambient Air Quality Monitoring	Sample Collected by	Laboratory
Sampling Location	1) Near Wagholi gate 2) Mr.Rahul Nakade House Village-Dawargaon 3) Ramkirshna Temple, Village-Kapustalani	Sample Quantity / Packing	Filter Paper (PM ₁₀): 3 X 3 No. Filter Paper (PM _{2.5}): 1 X 3 No. SO ₂ : 30mL X18 No. PVC Bottle NO ₂ : 30 mLX18 No. PVC Bottle NH ₃ : 10mL X18 No. PVC Bottle O ₃ : 10 mL X72 No. PVC Bottle 3 X 12 No. Charcoal Tubes 3 X 3 No. Rubber Bladder
Date of Sampling	26.03.2018 & 27.03.2018	Date of Receipt of Sample	27.03.2018
Sampling Procedure	As per Method Reference		
Date of Start of Analysis	28.03.2018	Date of Completion of Analysis	04.04.2018

Meteorological Data /Environmental Conditions						
Avg. Wind Velocity	Prominent Wind Direction		Relative Humidity (%)		Temperature (°C)	
2.7 km/h	SE		Max.	Min.	Max.	Min.
			54	28	38.0	20.0
Location :1) Near Wagholi gate				Duration of Survey 24 hours		
Parameter	Unit	Result	#NAAQM Standard	Method Reference		
Sulphur Dioxide (SO ₂)	µg/m ³	15.4	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6		
Nitrogen Dioxide (NO ₂)	µg/m ³	18.3	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10		
Particulate Matter (size less than 10µm) or PM ₁₀	µg/m ³	82	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14		
Particulate Matter (size less than 2.5µm) or PM _{2.5}	µg/m ³	44	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13,Page No.15-30		
Ozone (O ₃)	µg/m ³	<19.6	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13,Page No.31-34		

Report No.5094 cont...


Parameter	Unit	Result	#NAAQM Standard	Method Reference
Lead (as Pb)	µg/m ³	<0.02	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Carbon Monoxide (CO)	mg/m ³	0.82	4.0	IS 5182 (Part 10):1999 RA 2003
Ammonia (NH ₃)	µg/m ³	30.2	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
Benzene (C ₆ H ₆)	ng/m ³	1.1	5.0	IS 5182 (Part 11): 2006
Benzo(a)Pyrene (Particulate phase only)	µg/m ³	<0.5	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
Arsenic (as As)	ng/m ³	<0.3	6.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Nickel (as Ni)	ng/m ³	<3	20.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Mercury (as Hg)	µg/m ³	<0.06	-	Method of analysis of Hg & MoF Japan
Location : 2) Mr.Rahul Nakade House Village-Dawargaon				Duration of Survey 24 hours
Parameter	Unit	Result	#NAAQM Standard	Method Reference
Sulphur Dioxide (SO ₂)	µg/m ³	12.6	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
Nitrogen Dioxide (NO ₂)	µg/m ³	14.3	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
Particulate Matter (size less than 10µm) or PM ₁₀	µg/m ³	70	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
Particulate Matter (size less than 2.5µm) or PM _{2.5}	µg/m ³	38	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13,Page No.15-30
Ozone (O ₃)	µg/m ³	<19.6	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13,Page No.31-34
Lead (as Pb)	µg/m ³	<0.02	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Carbon Monoxide (CO)	mg/m ³	0.72	4.0	IS 5182 (Part 10):1999 RA 2003
Ammonia (NH ₃)	µg/m ³	27.6	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
Benzene (C ₆ H ₆)	ng/m ³	<1.0	5.0	IS 5182 (Part 11): 2006
Benzo(a)Pyrene (Particulate phase only)	µg/m ³	<0.5	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
Arsenic (as As)	ng/m ³	<0.3	6.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Nickel (as Ni)	ng/m ³	<3	20.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Mercury (as Hg)	µg/m ³	<0.06	-	Method of analysis of Hg & MoF Japan

Report No.5094 cont...

Parameter	Unit	Result	#NAAQM Standard	Method Reference
Location : 3) Ramkirshna Temple Vill- Kapustalani				Duration of Survey 24 hours
Sulphur Dioxide (SO ₂)	µg/m ³	12.3	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
Nitrogen Dioxide (NO ₂)	µg/m ³	14.8	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
Particulate Matter (size less than 10µm) or PM ₁₀	µg/m ³	77	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
Particulate Matter (size less than 2.5µm) or PM _{2.5}	µg/m ³	42	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
Ozone (O ₃)	µg/m ³	<19.6	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34
Lead (as Pb)	µg/m ³	<0.02	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Carbon Monoxide (CO)	mg/m ³	0.70	4.0	IS 5182 (Part 10):1999 RA 2003
Ammonia (NH ₃)	µg/m ³	28.6	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
Benzene (C ₆ H ₆)	ng/m ³	<1.0	5.0	IS 5182 (Part 11): 2006
Benzo(a)Pyrene (Particulate phase only)	µg/m ³	<0.5	1.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
Arsenic (as As)	ng/m ³	<0.3	6.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Nickel (as Ni)	ng/m ³	<3	20.0	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.48-55
Mercury (as Hg)	µg/m ³	<0.06	-	Method of analysis of Hg & MoF Japan
Remarks: N.D. - Not Detected; TWA - Time Weighted Average., #- NAAQS specified as: 24h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM ₁₀ , PM _{2.5} , Lead and Ammonia; 1h. TWA in case of Carbon Monoxide and Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.				

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole
BRANCH MANAGER


Note:

- The result listed refers only to the tested sample(s) and applicable parameter(s).
- This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagpur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5001-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description / Type	Ground Water/Grab	Sample Collected by	Laboratory
Sampling Location	Well Water of Shri Madhukarrao Dhote field, Village-Kapustalni	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018
Water Level Depth	6.22 meter from ground level		

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
1.	Colour	Hazen	<1	5 Max.	APHA 23 rd Ed. 2017, 2120-B, 2-6
2.	Odour	-	Agreeable	Agreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3.	Taste	-	Agreeable	Agreeable	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4.	Turbidity	NTU	0.18	1 Max.	APHA 23 rd Ed. 2017, 2130-B, 2-13
5.	pH	-	7.2	6.5 to 8.5	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6.	Total Dissolved Solids	mg/L	528	500 Max.	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7.	Suspended Solids	mg/L	<5	--	APHA 23 rd Ed. 2017, 2540-D, 2-69
8.	Residual Free Chlorine	ppm	<0.05	0.2 Min.	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9.	Total Hardness (as CaCO ₃)	mg/L	262	200 Max.	APHA 23 rd Ed. 2017, 2340-C, 2-48
10.	Alkalinity Total (as CaCO ₃)	mg/L	248	200 Max	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11.	Chloride(as Cl)	mg/L	58.2	250 Max.	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75



Report No.5001 Cont...

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
12.	Sulphate (as SO ₄)	mg/L	38.6	200 Max	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199
13.	Nitrate (as NO ₃)	mg/L	38.9	45 Max	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131
14.	Calcium (as Ca)	mg/L	72.8	75 Max.	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15.	Magnesium (as Mg)	mg/L	19.6	30 Max.	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16.	Fluoride(as F)	mg/L	0.684	1.0 Max.	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17.	Boron(as B)	mg/L	<0.1	0.5 Max.	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18.	Dissolved Oxygen	mg/L	6.5	--	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19.	Oil and Grease	mg/L	N.D.	--	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20.	Iron (as Fe)	mg/L	0.127	0.3 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
21.	Manganese (as Mn)	mg/L	<0.04	0.1 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22.	Cadmium (as Cd)	mg/L	N.D.	0.003 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23.	Copper (as Cu)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24.	Chromium Hexa (as Cr ⁶⁺)	mg/L	N.D.	--	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25.	Lead (as Pb)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26.	Zinc (as Zn)	mg/L	0.032	5 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
27.	Arsenic (as As)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28.	Mercury (as Hg)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29.	Selenium (as Se)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30.	Aluminium (as Al)	mg/L	<0.020	0.03 Max.	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31.	Cyanide (as CN)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32.	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected					

-END-

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C. Yeole

BRANCH MANAGER



Note:

- The result listed refers only to the tested sample(s) and applicable parameter(s).
- This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5002-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901	Order Reference:	
		SO No. 3382012035 dtd. 21.09.2015.	
Sample Description / Type	Ground Water/Grab	Sample Collected by	Laboratory
Sampling Location	Borewell- Gram Panchayat Digargoan	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
1.	Colour	Hazen	<1	5 Max.	APHA 23 rd Ed. 2017, 2120-B, 2-6
2.	Odour	-	Agreeable	Agreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3.	Taste	-	Agreeable	Agreeable	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4.	Turbidity	NTU	0.28	1 Max.	APHA 23 rd Ed. 2017, 2130-B, 2-13
5.	pH	-	6.8	6.5 to 8.5	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6.	Total Dissolved Solids	mg/L	732	500 Max.	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7.	Suspended Solids	mg/L	<5	--	APHA 23 rd Ed. 2017, 2540-D, 2-69
8.	Residual Free Chlorine	ppm	<0.05	0.2 Min.	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9.	Total Hardness (as CaCO ₃)	mg/L	404	200 Max.	APHA 23 rd Ed. 2017, 2340-C, 2-48
10.	Alkalinity Total (as CaCO ₃)	mg/L	368	200 Max	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11.	Chloride(as Cl)	mg/L	108	250 Max.	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75
12.	Sulphate (as SO ₄)	mg/L	42.6	200 Max	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199



Report No.5002 Cont...

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
13.	Nitrate (as NO ₃)	mg/L	68.4	45 Max	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131
14.	Calcium (as Ca)	mg/L	70.6	75 Max.	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15.	Magnesium (as Mg)	mg/L	55.4	30 Max.	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16.	Fluoride(as F)	mg/L	0.478	1.0 Max.	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17.	Boron(as B)	mg/L	<0.1	0.5 Max.	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18.	Dissolved Oxygen	mg/L	6.5	--	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19.	Oil and Grease	mg/L	N.D.	--	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20.	Iron (as Fe)	mg/L	0.228	0.3 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
21.	Manganese (as Mn)	mg/L	<0.04	0.1 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22.	Cadmium (as Cd)	mg/L	N.D.	0.003 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23.	Copper (as Cu)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24.	Chromium Hexa (as Cr ⁶⁺)	mg/L	N.D.	--	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25.	Lead (as Pb)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26.	Zinc (as Zn)	mg/L	0.020	5 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
27.	Arsenic (as As)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28.	Mercury (as Hg)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29.	Selenium (as Se)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30.	Aluminium (as Al)	mg/L	<0.005	0.03 Max.	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31.	Cyanide (as CN)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32.	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected					

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C. Yeole

BRANCH MANAGER



Note:

- The result listed refers only to the tested sample(s) and applicable parameter(s).
- This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5003-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description / Type	Ground Water/Grab	Sample Collected by	Laboratory
Sampling Location	Well Water Gram Panchayat Pimpal Vihargaon	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018
Water Level Depth	3.55 meter from ground level		

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
1.	Colour	Hazen	<1	5 Max.	APHA 23 rd Ed. 2017, 2120-B, 2-6
2.	Odour	-	Agreeable	Agreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3.	Taste	-	Agreeable	Agreeable	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4.	Turbidity	NTU	0.28	1 Max.	APHA 23 rd Ed. 2017, 2130-B, 2-13
5.	pH	-	7.5	6.5 to 8.5	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6.	Total Dissolved Solids	mg/L	362	500 Max.	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7.	Suspended Solids	mg/L	<5	-	APHA 23 rd Ed. 2017, 2540-D, 2-69
8.	Residual Free Chlorine	ppm	<0.05	0.2 Min.	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9.	Total Hardness (as CaCO ₃)	mg/L	255	200 Max.	APHA 23 rd Ed. 2017, 2340-C, 2-48
10.	Alkalinity Total (as CaCO ₃)	mg/L	258	200 Max	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11.	Chloride(as Cl)	mg/L	13.3	250 Max.	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75
12.	Sulphate (as SO ₄)	mg/L	11.8	200 Max	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199



Report No.5003 Cont...

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
13.	Nitrate (as NO ₃)	mg/L	6.78	45 Max	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131
14.	Calcium (as Ca)	mg/L	65.8	75 Max.	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15.	Magnesium (as Mg)	mg/L	22.1	30 Max.	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16.	Fluoride(as F)	mg/L	0.478	1.0 Max.	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17.	Boron(as B)	mg/L	<0.1	0.5 Max.	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18.	Dissolved Oxygen	mg/L	6.5	-	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19.	Oil and Grease	mg/L	N.D.	-	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20.	Iron (as Fe)	mg/L	0.187	0.3 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
21.	Manganese (as Mn)	mg/L	N.D.	0.1 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22.	Cadmium (as Cd)	mg/L	N.D.	0.003 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23.	Copper (as Cu)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24.	Chromium Hexa (as Cr ⁶⁺)	mg/L	N.D.	-	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25.	Lead (as Pb)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26.	Zinc (as Zn)	mg/L	0.038	5 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
27.	Arsenic (as As)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28.	Mercury (as Hg)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29.	Selenium (as Se)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30.	Aluminium (as Al)	mg/L	0.003	0.03 Max.	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31.	Cyanide (as CN)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32.	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected					

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C.Yeole

BRANCH MANAGER

Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagpur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5004-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description / Type	Ground Water/Grab	Sample Collected by	Laboratory
Sampling Location	Well Water of Shri Arun Ghathode Vill. Rasalpur	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018
Water Level Depth	12.4 meter from ground level		

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
1.	Colour	Hazen	<1.1	5 Max.	APHA 23 rd Ed. 2017, 2120-B, 2-6
2.	Odour	-	Agreeable	Agreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3.	Taste	-	Agreeable	Agreeable	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4.	Turbidity	NTU	0.25	1 Max.	APHA 23 rd Ed. 2017, 2130-B, 2-13
5.	pH	-	7.3	6.5 to 8.5	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6.	Total Dissolved Solids	mg/L	874	500 Max.	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7.	Suspended Solids	mg/L	<5	--	APHA 23 rd Ed. 2017, 2540-D, 2-69
8.	Residual Free Chlorine	ppm	<0.05	0.2 Min.	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9.	Total Hardness (as CaCO ₃)	mg/L	289	200 Max.	APHA 23 rd Ed. 2017, 2340-C, 2-48
10.	Alkalinity Total (as CaCO ₃)	mg/L	280	200 Max	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11.	Chloride(as Cl)	mg/L	42.7	250 Max.	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75
12.	Sulphate (as SO ₄)	mg/L	88.9	200 Max	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199

Page 1 of 2



Report No.5004 Cont...

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
13.	Nitrate (as NO ₃)	mg/L	30.9	45 Max	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131
14.	Calcium (as Ca)	mg/L	62.8	75 Max.	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15.	Magnesium (as Mg)	mg/L	32.1	30 Max.	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16.	Fluoride(as F)	mg/L	0.818	1.0 Max.	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17.	Boron(as B)	mg/L	<0.1	0.5 Max.	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18.	Dissolved Oxygen	mg/L	6.5	--	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19.	Oil and Grease	mg/L	N.D.	--	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20.	Iron (as Fe)	mg/L	0.188	0.3 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
21.	Manganese (as Mn)	mg/L	<0.04	0.1 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22.	Cadmium (as Cd)	mg/L	N.D.	0.003 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23.	Copper (as Cu)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24.	Chromium Hexa (as Cr ⁶⁺)	mg/L	N.D.	--	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25.	Lead (as Pb)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26.	Zinc (as Zn)	mg/L	0.021	5 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
27.	Arsenic (as As)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28.	Mercury (as Hg)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29.	Selenium (as Se)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30.	Aluminium (as Al)	mg/L	0.020	0.03 Max.	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31.	Cyanide (as CN)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32.	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected					

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C. Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.
- 3.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5005-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description / Type	Ground Water/Grab	Sample Collected by	Laboratory
Sampling Location	Well Water of Shri Shyamroaji Zode House Village-Talkhanda	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018
Water Level Depth	4.74 meter from ground level		

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
1.	Colour	Hazen	<1	5 Max.	APHA 23 rd Ed. 2017, 2120-B, 2-6
2.	Odour	-	Agreeable	Agreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3.	Taste	-	Agreeable	Agreeable	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4.	Turbidity	NTU	0.15	1 Max.	APHA 23 rd Ed. 2017, 2130-B, 2-13
5.	pH	-	7.6	6.5 to 8.5	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6.	Total Dissolved Solids	mg/L	426	500 Max.	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7.	Suspended Solids	mg/L	<5	--	APHA 23 rd Ed. 2017, 2540-D, 2-69
8.	Residual Free Chlorine	ppm	<0.05	0.2 Min.	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9.	Total Hardness (as CaCO ₃)	mg/L	338	200 Max.	APHA 23 rd Ed. 2017, 2340-C, 2-48
10.	Alkalinity Total (as CaCO ₃)	mg/L	248	200 Max	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11.	Chloride(as Cl)	mg/L	26.2	250 Max.	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75



Report No.5005 Cont...

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
12.	Sulphate (as SO ₄)	mg/L	38.6	200 Max	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199
13.	Nitrate (as NO ₃)	mg/L	16.2	45 Max	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131
14.	Calcium (as Ca)	mg/L	84.5	75 Max.	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15.	Magnesium (as Mg)	mg/L	30.8	30 Max.	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16.	Fluoride(as F)	mg/L	0.438	1.0 Max.	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17.	Boron(as B)	mg/L	<0.1	0.5 Max.	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18.	Dissolved Oxygen	mg/L	6.8	--	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19.	Oil and Grease	mg/L	N.D.	--	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20.	Iron (as Fe)	mg/L	0.256	0.3 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
21.	Manganese (as Mn)	mg/L	<0.04	0.1 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22.	Cadmium (as Cd)	mg/L	N.D.	0.003 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23.	Copper (as Cu)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24.	Chromium Hexa (as Cr ⁶⁺)	mg/L	N.D.	--	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25.	Lead (as Pb)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26.	Zinc (as Zn)	mg/L	0.038	5 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
27.	Arsenic (as As)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28.	Mercury (as Hg)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29.	Selenium (as Se)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30.	Aluminium (as Al)	mg/L	<0.012	0.03 Max.	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31.	Cyanide (as CN)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32.	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected					

-END-

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C.Yeole

BRANCH MANAGER



Note:

- The result listed refers only to the tested sample(s) and applicable parameter(s).
- This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5006-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description / Type	Ground Water/Grab	Sample Collected by	Laboratory
Sampling Location	Dugwell of Wagholi Village	Sample Quantity/Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	17.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
1.	Colour	Hazen	<1	5 Max.	APHA 23 rd Ed. 2017, 2120-B, 2-6
2.	Odour	-	Agreeable	Agreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3.	Taste	-	Agreeable	Agreeable	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4.	Turbidity	NTU	<0.1	1 Max.	APHA 23 rd Ed. 2017, 2130-B, 2-13
5.	pH	-	7.7	6.5 to 8.5	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6.	Total Dissolved Solids	mg/L	432	500 Max.	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7.	Suspended Solids	mg/L	<5	--	APHA 23 rd Ed. 2017, 2540-D, 2-69
8.	Residual Free Chlorine	ppm	<0.05	0.2 Min.	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9.	Total Hardness (as CaCO ₃)	mg/L	371	200 Max.	APHA 23 rd Ed. 2017, 2340-C, 2-48
10.	Alkalinity Total (as CaCO ₃)	mg/L	322	200 Max	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11.	Chloride(as Cl)	mg/L	36.5	250 Max.	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75
12.	Sulphate (as SO ₄)	mg/L	48.9	200 Max	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199



Report No.5006 Cont...

Sr. No.	Parameter	Unit	Result	Acceptable Limit for Drinking water (IS 10500:2012)	Method Reference
13.	Nitrate (as NO ₃)	mg/L	22.6	45 Max	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131
14.	Calcium (as Ca)	mg/L	94.8	75 Max.	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15.	Magnesium (as Mg)	mg/L	32.8	30 Max.	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16.	Fluoride(as F)	mg/L	0.528	1.0 Max.	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17.	Boron(as B)	mg/L	<0.1	0.5 Max.	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18.	Dissolved Oxygen	mg/L	6.7	--	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19.	Oil and Grease	mg/L	N.D.	--	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20.	Iron (as Fe)`	mg/L	0.228	0.3 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
21.	Manganese (as Mn)	mg/L	<0.04	0.1 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22.	Cadmium (as Cd)	mg/L	N.D.	0.003 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23.	Copper (as Cu)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24.	Chromium Hexa (as Cr ⁶⁺)	mg/L	N.D.	--	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25.	Lead (as Pb)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26.	Zinc (as Zn)	mg/L	0.027	5 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
27.	Arsenic (as As)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28.	Mercury (as Hg)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29.	Selenium (as Se)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30.	Aluminium (as Al)	mg/L	<0.02	0.03 Max.	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31.	Cyanide (as CN)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32.	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	0.001 Max.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected					

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C.Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5008-180328-SA-RIPL-AMRAVATI		Date: 28.03.2018	
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901	Order Reference:	
		SO No. 3382012035 dtd. 21.09.2015.	
Sample Description / Type	Surface water/Grab	Sample Collected by	Laboratory
Sampling Location	Malegaon Pond	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018

Sr. No.	Parameter	Unit	Result	Method Reference
1	Colour	Hazen	<1	APHA 23 rd Ed. 2017, 2120-B, 2-6
2	Odour	-	Agreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3	Taste	-	NA	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4	Turbidity	NTU	22	APHA 23 rd Ed. 2017, 2130-B, 2-13
5	pH	-	8.1	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6	Total Dissolved Solids	mg/L	238	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7	Total Suspended Solids	mg/L	48	APHA 23 rd Ed. 2017, 2540-D, 2-69
8	Free Chlorine (Residual)	mg/L	<0.05	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9	Total Hardness (as CaCO ₃)	mg/L	162	APHA 23 rd Ed. 2017, 2340-C, 2-48
10	Alkalinity Total (as CaCO ₃)	mg/L	134	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11	Chloride (as Cl)	mg/L	20.2	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75
12	Sulphate (as SO ₄)	mg/L	16.8	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199
13	Nitrate (as NO ₃)	mg/L	0.678	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131



Report No.5008 cont.

Sr. No.	Parameter	Unit	Result	Method Reference
14	Calcium(as Ca)	mg/L	34.8	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15	Magnesium (as Mg)	mg/L	18.2	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16	Fluoride(as F)	mg/L	0.532	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17	Boron(as B)	mg/L	<0.1	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18	Dissolved Oxygen	mg/L	6.8	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19	Oil and Grease	mg/L	N.D.	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20	Iron (as Fe)	mg/L	0.728	APHA 23 rd Ed. 2017, 3111-B, 3-20
21	Manganese (as Mn)	mg/L	0.120	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22	Cadmium (as Cd)	mg/L	0.015	APHA 23 rd Ed. 2017, 3111-B, 3-20
23	Copper (as Cu)	mg/L	0.005	APHA 23 rd Ed. 2017, 3111-B, 3-20
24	Chromium Hexa (as Cr ⁶⁺)	mg/L	0.009	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25	Lead (as Pb)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26	Zinc (as Zn)	mg/L	0.0298	APHA 23 rd Ed. 2017, 3111-B, 3-20
27	Arsenic (as As)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28	Mercury (as Hg)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29	Selenium (as Se)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30	Aluminium (as Al)	mg/L	0.003	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31	Cyanide (as CN)	mg/L	N.D.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected,				

END

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C.Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5009-180328-SA-RIPL-AMRAVATI		Date: 28.03.2018	
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901	Order Reference:	
		SO No. 3382012035 dtd. 21.09.2015.	
Sample Description / Type	Surface water/Grab	Sample Collected by	Laboratory
Sampling Location	Wagholi Pond	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018

Sr. No.	Parameter	Unit	Result	Method Reference
1	Colour	Hazen	17	APHA 23 rd Ed. 2017, 2120-B, 2-6
2	Odour	-	Disagreeable	IS 3025 (Part 05):1984, Reaffirmed 2006
3	Taste	-	NA	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4	Turbidity	NTU	3.2	APHA 23 rd Ed. 2017, 2130-B, 2-13
5	pH	-	7.8	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6	Total Dissolved Solids	mg/L	438	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7	Total Suspended Solids	mg/L	36	APHA 23 rd Ed. 2017, 2540-D, 2-69
8	Free Chlorine (Residual)	mg/L	0.082	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9	Total Hardness (as CaCO ₃)	mg/L	257	APHA 23 rd Ed. 2017, 2340-C, 2-48
10	Alkalinity Total (as CaCO ₃)	mg/L	188	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11	Chloride (as Cl)	mg/L	48.2	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75
12	Sulphate (as SO ₄)	mg/L	88.6	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199
13	Nitrate (as NO ₃)	mg/L	0.548	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131



Report No.5009 cont.

Sr. No.	Parameter	Unit	Result	Method Reference
14	Calcium (as Ca)	mg/L	56.4	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
15	Magnesium (as Mg)	mg/L	28.1	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16	Fluoride(as F)	mg/L	0.538	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17	Boron(as B)	mg/L	<0.1	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18	Dissolved Oxygen	mg/L	6.3	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19	Oil and Grease	mg/L	N.D.	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20	Iron (as Fe)	mg/L	0.685	APHA 23 rd Ed. 2017, 3111-B, 3-20
21	Manganese (as Mn)	mg/L	<0.04	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22	Cadmium (as Cd)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23	Copper (as Cu)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24	Chromium Hexa (as Cr ⁶⁺)	mg/L	0.028	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25	Lead (as Pb)	mg/L	<0.1	APHA 23 rd Ed. 2017, 3111-B, 3-20
26	Zinc (as Zn)	mg/L	0.019	APHA 23 rd Ed. 2017, 3111-B, 3-20
27	Arsenic (as As)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28	Mercury (as Hg)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29	Selenium (as Se)	mg/L	N.D.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30	Aluminium (as Al)	mg/L	<0.004	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31	Cyanide (as CN)	mg/L	N.D.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: N.D. – Not Detected,				

END

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C. Yeole

BRANCH MANAGER



Note:

- The result listed refers only to the tested sample(s) and applicable parameter(s).
- This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Water Sample Analysis Report

Report No.: ME-NG5007-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			Service Order No. 3382014804 dtd. 19.08.2017
Sample Description / Type	Surface Water/Grab	Sample Collected by	Laboratory
Sampling Location	Back side of Ash Dyke area well of Mr. Vasant Pachghare	Sample Quantity / Packing	3 L X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	16.03.2018	Date of Receipt of Sample	16.03.2018
Sampling Procedure	IS:3025(Part I):1987 RA 2003; APHA 23 rd Ed. 2017, 1060-B, 1-40;		
Date of Start of Analysis	17.03.2018	Date of Completion of Analysis	26.03.2018
Water Level Depth	-		

Sr. No.	Parameter	Unit	Result	Inland Surface water (EPA rule 1986)	Method Reference
1.	Colour	Hazen	<1	-	APHA 23 rd Ed. 2017, 2120-B, 2-6
2.	Odour	-	Agreeable	-	IS 3025 (Part 05):1984, Reaffirmed 2006
3.	Taste	-	Disagreeable	-	IS 3025 (Part 7 & 8):1984, Reaffirmed 2006
4.	Turbidity	NTU	2.2	-	APHA 23 rd Ed. 2017, 2130-B, 2-13
5.	pH	-	8.1	5.5 to 9.0	APHA 23 rd Ed. 2017, 4500-H ⁺ -B, 4-95
6.	Total Dissolved Solids	mg/L	452	-	IS 3025 (Part 16):1984 Reaffirmed 2006, Ed.2.1(1999-12)
7.	Suspended Solids	mg/L	52	100 Max.	APHA 23 rd Ed. 2017, 2540-D, 2-69
8.	Residual Free Chlorine	ppm	N.D.	1.0 Max.	APHA 23 rd Ed. 2017, 4500-Cl G, 4-72
9.	Total Hardness (as CaCO ₃)	mg/L	268	-	APHA 23 rd Ed. 2017, 2340-C, 2-48
10.	Alkalinity Total (as CaCO ₃)	mg/L	256	-	IS 3025 (Part 23):1986 Reaffirmed 2009 Amds 1
11.	Chloride(as Cl)	mg/L	19.4	-	APHA 23 rd Ed. 2017, 4500-Cl-B, 4-75
12.	Sulphate (as SO ₄)	mg/L	15.8	-	APHA 23 rd Ed. 2017, 4500- SO ₄ -E, 4-199




Report No.5007 Cont...

Sr. No.	Parameter	Unit	Result	Inland Surface water (EPA rule 1986)	Method Reference
13.	Nitrate (as NO ₃)	mg/L	22.8	-	APHA 23 rd Ed. 2017, 4500-NO ₃ , E 4-131
15.	Calcium (as Ca)	mg/L	45.6	-	APHA 23 rd Ed. 2017, 3500-Ca-B, 3-69
14.	Magnesium (as Mg)	mg/L	37.4	-	APHA 23 rd Ed. 2017, 3500-Mg- B, 3-86
16.	Fluoride(as F)	mg/L	0.328	2.0 Max.	APHA 23 rd Ed. 2017, 4500-F, D, 4-90
17.	Boron(as B)	mg/L	<0.1	-	APHA 23 rd Ed. 2017, 4500-B B, 4-27
18.	Dissolved Oxygen	mg/L	5.5	-	APHA 23 rd Ed. 2017, 4500-O, B & C, 4-144, 4-146
19.	Oil and Grease	mg/L	N.D.	10 Max.	IS 3025 (Part 39): 1991, Reaffirmed 2009, Amds.1
20.	Iron (as Fe)	mg/L	0.328	3.0 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
21.	Manganese (as Mn)	mg/L	<0.04	2.0 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20 AAS Method
22.	Cadmium (as Cd)	mg/L	N.D.	2.0 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
23.	Copper (as Cu)	mg/L	N.D.	3.0 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
24.	Chromium Hexa (as Cr ⁶⁺)	mg/L	N.D.	0.1 Max.	APHA 23 rd Ed. 2017, 3500- Cr-B, 3-71
25.	Lead (as Pb)	mg/L	N.D.	0.1 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
26.	Zinc (as Zn)	mg/L	0.018	5.0 Max.	APHA 23 rd Ed. 2017, 3111-B, 3-20
27.	Arsenic (as As)	mg/L	N.D.	0.2 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
28.	Mercury (as Hg)	mg/L	N.D.	0.01 Max.	APHA 23 rd Ed. 2017, 3112-B, 3-25
29.	Selenium (as Se)	mg/L	N.D.	0.05 Max.	APHA 23 rd Ed. 2017, 3114-C, 3-40
30.	Aluminium (as Al)	mg/L	0.025	-	APHA 23 rd Ed. 2017, 3500-Al-B, 3-63
31.	Cyanide (as CN)	mg/L	N.D.	0.2 Max.	APHA 23 rd Ed. 2017, 4500-CN, C & E, 4-44 & 4-46
32.	Phenolic Compounds (as C ₆ H ₅ OH)	mg/L	N.D.	1.0 Max.	APHA 23 rd Ed. 2017, 5530- B & C, 5-49, 5-50
Remarks: Limit is EPA Rule 1986 of Schedule VI (rule 3A) of General Standard for Discharge of Environmental Pollutants Part A Effluents Detected.					

-END-

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.


Kishor C. Yeole
BRANCH MANAGER



Note:

- The result listed refers only to the tested sample(s) and applicable parameter(s).
- This report is not to be reproduced except in full, without written approval of the laboratory.



Mahabal Enviro Engineers Pvt. Ltd.

Engineers, Consultants, Environmental Monitoring Laboratory & Contractors

Plot Nos. 13,14,17,18, Grampanchayat Bokhara, 8 km from Nagpur City,

Opp. Patel Petrol Pump, Chhindwara Road, Koradi, Dist.Nagapur-441111

Phone : 91-712-2612162 T/Fax: 91-712-2612212 Email: nagpur@mahabal.com

Noise Level Monitoring Report

Report No.: ME-NG5000-180328-SA-RIPL-AMRAVATI			Date: 28.03.2018
Name and Address of Customer	RATTANINDIA POWER LIMITED Plot No.D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901		Order Reference:
			SO No. 3382012035 dtd. 21.09.2015.
Sample Description / Type	Noise Level Monitoring	Sample Collected by	Laboratory
Date of Sampling	16.03.2018		
Sampling Procedure	Instrument Catalogue & User manual		

Location	Unit	Result		Norms as per factory Act.	
		Min.	Max.	Maximum Exposure duration per Day	Limit
Green Point gate	dB(A)	68.8	77.2	8 h	90 Max.
Wagholi gate	dB(A)	76.2	80.6		
Near Material gate	dB(A)	74.2	78.9		
Near Labour Colony	dB(A)	67.1	74.8		
Near Bachelor Colony Building	dB(A)	68.6	75.1		
Remark: : Limit from The Factories Act, 1948, The Maharashtra Factory Rules, 1963, Schedule XXIV Page No. 283-284					

-----END-----

FOR MAHABAL ENVIRO ENGINEERS PVT. LTD.

Kishor C.Yeole

BRANCH MANAGER



Note:

1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without written approval of the laboratory.